## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 7165-1157:100 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Digital Monitoring Products, 2500 N. Partnership Blvd, Springfield MO 65803

Contact: Terry Shelton (417) 831-9362 FAX (417) 831-1325

**DESIGN**: Models SCS-1 and \*SCS-1R security control receivers, suitable for use as central station fire,

\*remote station fire, and burglary applications; and Model 1812 command processor

fire/burglary control unit and accessory modules. System components:

1812A, B, C, D, E Command Processor Control Panel

320, 321, 322 Transformers
704, 705, 714, 715 Loop Expander
318 Battery Hardness

 367
 Battery

 866
 Bell Module

 670, 770, 771
 Keypads

984D, D1, D2, DB, M, MB, MD, Communication Modules

984X1, X1B, X2, X2B

iCOM Internet Alarm Router

iCOM-E Encrypted Internet Alarm Router

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

**MARKING**: Listee's name, model numbers, electrical rating, and UL label.

APPROVAL: Listed as a control unit when used with separately listed compatible initiating and indicating

devices. In commercial application, the keypad which displays fire alarms and troubles must be connected to Model 1812 through conduit and located in the same room as the control unit.

These control units do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instruction Manual

for details.

**NOTE**: Burglary and other non-fire functions were not examined.

\*Rev. 11-12-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 22, 2004 Listing Expires June 30, 2005

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager